

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 118209
Permit No. _____
Basin 057

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70224

1 OWNER Rod Monk ADDRESS AT WELL LOCATION Antelope Valley
MAILING ADDRESS HC 61 Box 180 Battle Mountain, NV 89820
Battle Mountain, NV 89820 Subdivision Name: _____ County: Lander

2 LOCATION NE ¼ NE ¼ Sec 15 T 24N N/S R 40 E Latitude 39.95985N UTM E _____ NAD 27
PERMIT/WAIVER No. _____ Longitude -117.45365W N _____ NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3 TYPE OF WELL Is this well being plugged because a replacement well was drilled? no Is there an existing well log? NO
 Domestic Irrigation Test Municipal/Industrial Monitor Stock If yes, what is replacement well NOI? _____ If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42	.250	0	340

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____
Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made: _____

Existing Perforations:
Type of perforation _____
Size of perforation _____

From	feet to	feet

Additional Perforations:
Type of perforator used: Mill Knife

From	feet to	feet	Number of perfs per linear foot
0	340		8

5 WATER LEVEL
Static water level 170 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I. _____
Water temperature cool °F Quality unknown

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
340	50		20% Bentonite Grout	<input checked="" type="checkbox"/>	<input type="checkbox"/>
50	0		Neat Cement	<input checked="" type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments
Pumped 20% Bentonite Grout from 340' to 50'
Neat cement from 50' to surface.

NAD 27
39.95985N
117.45365W

Neat Cement Fluid Weight 15.6 lbs/gal
Bentonite Grout 20 % bentonite
Date Started 8/20/2013
Date Completed 8/23/2013

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc
Contractor
Address P.O. Box 1265
Contractor
Fallon, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2307

Signed Wayne Parsons
Date 9/5/2013