STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118209
Permit No. 82477
Basin No. 177

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70197
WELL NAME *(If applicable)*: N/A

1. OWNER/CLIENT NAME Rodriguez Ranch
MAILING ADDRESS PO Box 515 Wells NV, 89835

DETAILED ADDRESS AT WELL LOCATION Rodriguez Ranch
Subdivision Name: *County:* Elko

2. PLS LOCATION NW ¼ SE ¼ 18 Sec 36 N/S 62 E
PERMIT/WAIVER NO. 82477 *Issued by Water Resources* *Current Parcel No.*

Latitude 41* 00.080 N UTM E ☐ NAD 27
Longitude 115* 00.485 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☒ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To	Thickness
Cobbles and Clay			0'	30'	30'
Green Clay			30'	55'	25'
Green Sand Stone			55'	161'	106'
Green Limestone			161'	260'	99'
Gray Claystone			260'	300'	40'
Brown Claystone			300'	310'	10'
This borehole did not look water producing so we abandon it to state regs. And put a 30' neat cement cap on it.					
		Nad 27			
		41.00 4100 N			
		115.00 7203			

Date started: 20-Aug, 20 13
Date completed: 25-Aug, 20 13

9. WELL CONSTRUCTION
Depth Drilled: 310' Feet Depth Cased: 0' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
36"	Inches	0'	Feet	30'	Feet
24"	Inches	30'	Feet	310'	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30"		.250"	0'	30'

PERFORATIONS:
Type of perforation: N/A
Size of perforation:
From Feet To Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal		to		
☒ Neat Cement	0'	to 30'	☒ Pumped	☐ Poured
☒ Cement Grout	0'	to 30'	☒ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☒ Other, explain:	30'	to 310'	☐ Pumped	☒ Poured

7. WATER QUALITIES
Static water level: N/A Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Hydro Resources-West, Inc. *Contractor*
Address 4975 W. Winnemucca Blvd. Winnemucca, NV 89445 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 56797
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller).* # 1713
Signed: Michelle Strother *By driller performing actual drilling on site or contractor*
Date: 9/23/13

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY