STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115230
Permit No.
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68470
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Dianna Blevins
MAILING ADDRESS 6528 Victor dr
Fallon NV 89406

DETAILED ADDRESS AT WELL LOCATION 6528 Victor dr
Fallon NV 89406
Subdivision Name: *County:* Churchill

2. PLS LOCATION NW¼ NE ¼ 31 Sec 20 N/S 28 E
PERMIT/WAIVER NO. 009-381-18
Issued by Water Resources *Current Parcel No.*

Latitude UTM E 0338254 ☒ NAD 27
Longitude UTM N 4380417 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # ?
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Brown Sand w/clays			0	39	39
Black & Green Sand w/ clays		X	39	85	46
colored Gravels		X	85	95	10
Black & Green Sand w/ clays		X	95	157	63
multi Color Sand		X	157	160	3
Brown Clay			160	164	4
Sand & Gravels		X	164	172	8

RECEIVED 2013 OCT 1 AM 10:40 STATE ENGINEERS OFFICE

NAD27
39.56 0089 N
118.88 2735 W

Date started: 10-1 , 20 13
Date completed: 10-3 , 20 13

7. WATER QUALITIES
Static water level: 26' Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
35		2 hrs
Replaces unknown well log		

9. WELL CONSTRUCTION
Depth Drilled: 172 Feet Depth Cased: 172 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
6 5/8	Inches	50	Feet	172	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	172

PERFORATIONS:
Type of perforation: factory slots
Size of perforation: .008
From 164 Feet To 171 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal	0 to 50			
☒ Neat Cement	0 to 50		☒ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ Bentonite Chips	to		☐ Pumped	☐ Poured
☐ Bentonite Grout	to		☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☐ Gravel Pack [> 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Other, explain:	to		☐ Pumped	☐ Poured

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Welsco drilling *Contractor*
Address P.O Box 888 Fallon NV 89406 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* ~~1727~~ 11752
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1727
Signed: *By driller performing actual drilling on site or contractor*
Date: 10-3-13

(Rev. 08-12) **USE ADDITIONAL SHEETS IF NECESSARY**