STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118241
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70149

1. OWNER Hunter Quilici
MAILING ADDRESS 3130 Ether Way
Winnemucca NV.

ADDRESS AT WELL LOCATION 3130 Ether Way
Winnemucca NV.
Subdivision Name: County: Humboldt

2. LOCATION NW ¼ SE ¼ Sec 24 T 35 N/S R 37 E
PERMIT/WAIVER No. 014-103-19
Issued by Water Resources Parcel No.

Latitude N40° 53.428
Longitude W117°45.665
UTM E N
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Existing Well		0	155	155
Cemented Gravel				
Clay Sand		155	260	105
deepening unknown well log				
NAD 27				
40.8904670 N				
117.7610830 W				

Date started: 9-17, 20 13
Date completed: 9-21, 20 13

RECEIVED 2013 OCT -9 PM 12:43 STATE ENGINEERS OFFICE

7. Water Level
Static water level: 128 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	NA	4

9. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Existing	0 Inches	155 Feet
6 1/8"	155 Inches	260 Feet
	Inches	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	Steel	.188	0	155
4 1/8"	PVC	Sch 40	140	260

Perforations:
Type of perforation machined slot
Size of perforation .02
From 140 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

NA Annular Seal: ☐ Yes ☒ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Jungo Rd. (Contractor)
Winnemucca NV.
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed (By driller performing actual drilling on-site or contractor)
Date 9-21-13

(Rev. 05-05)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627