STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118242
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70146

1. OWNER Adel McNamara
MAILING ADDRESS 9425 Alice Ln.
se Winnemucca NV.

ADDRESS AT WELL LOCATION 9425 Alice Ln.
Winnemucca NV.
Subdivision Name: 2 BS
County: Humboldt

2. LOCATION SW ¼ NW ¼ Sec 30 T 35 N/S R 38 E
PERMIT/WAIVER No. 010-533-05
Issued by Water Resources Parcel No.

Latitude N 40° 52.827
Longitude W 117° 44.833
UTM E
N
☒ NAD 27
☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Existing Hole,	No	0	220	
Cemented Gravel	Yes	220	320	100
Sand Clay				
Begins Outnorm well log				
NAD27				
40.85088N				
117.7472195°W				

RECEIVED 2013 OCT -9 AM 12:13 STATE ENGINEERS OFFICE

Date started: 9-5-13, 20 13
Date completed: 9-7-13, 20 13

7. Water Level
Static water level: 205 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	NA	2

9. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
Existing	Inches	0	Feet	220	Feet
6 1/8"	Inches	220	Feet	320	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	220
4 5/8	PVC	Sched 40	200	320

Perforations:
Type of perforation Machine slot
Size of perforation .02
From 200 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☒ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Jungo Rd. (Contractor)
Winnemucca NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed (By driller performing actual drilling on-site or contractor)
Date 9-7-13

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627