STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118300
Permit No.
Basin No. 087

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66614
WELL NAME (if applicable):

1. OWNER/CLIENT NAME Lysle Winchester
MAILING ADDRESS 2250 Hedgewood Reno NV 89509

DETAILED ADDRESS AT WELL LOCATION 3155 Holcomb
Subdivision Name: County: Washoe

2. PLS LOCATION NE ¼ NW ¼ 12 Sec 18 N/S 19 E
PERMIT/WAIVER NO. 040-650-25
Issued by Water Resources Current Parcel No.

Latitude 39.44 409 UTM E ☒ NAD 27
Longitude 119.802 53 UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # 7
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Overburden			0	4	4
Cobbles			4	23	19
Rock brown/clay			23	121	98
gravels		x	121	143	22
brown clay			143	149	6
basalt		x	149	168	19
clay			168	175	7
fractured rock		x	175	238	63

STATE ENGINEER
2013
FACSIMILE RCVD

Date started: 3-Jan , 20 2012
Date completed: 7-Jan , 20 2012

9. WELL CONSTRUCTION
Depth Drilled: 238 Feet Depth Cased: 238 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	238	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	0.12	.188	+1	20
6		SDR21	20	238

PERFORATIONS:
Type of perforation: screen
Size of perforation: 0.04
From 198 Feet To 238 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☐ Sanitary Seal		to		
☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 100	☒ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	100	to 238	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 57 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold ° Fahrenheit
Water Quality: clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
25+		2.5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Blain Drilling & Pump INC
Contractor
Address Po Box1255 CC NV 89702
Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 46498
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2134
Signed:
By driller performing actual drilling at site or contractor
Date: Jan 27 2012

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY