STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118324
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69923 ✓

1. OWNER ARTISAN EAST LLC
MAILING ADDRESS 4940 LEO BINGO CT
WASHOE VALLEY, NV 89704

ADDRESS AT WELL LOCATION 1810 HAMILTON CREEK TRAIL
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION NE ¼ SW ¼ Sec 28 T 34N N/S R 55 E
PERMIT/WAIVER No. 69713-R11 (82527) 006-09P-111
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0602472 [X] NAD 27
N 4517359 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL STRIPPED				
SAND & GRAVEL		0	10	10
GRAY GREEN SAND & CLAY		10	80	70
GRAY BLACK VOLCANIC CLAY	X	80	170	90
BLACK SANDSTONE		170	180	10
BLACK VOLCANIC CLAY	XX	180	210	30
LIGHT GRAY VOLCANIC		210	220	10
1ST WATER	X	140		
2ND WATER	XX	200		

Date started: 4-Mar, 20 13
Date completed: 5-Mar, 20 13

7. Water Level
Static water level: 64 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 70 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AT 215'	75		2 HOURS
AT 160'	50		1/4 HOUR
AT 120'	40		
AT 100'	20		
NAD27	40.802743°N		
	115.785228°W		

9. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 219 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+1 1/2	59
6.625	4	SDR 21 .316	59	219

Perforations:
Type of perforation SLOTTED
Size of perforation .025 6 ROW
From 199 feet to 219 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 4 to 25 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 55 to 220 [ ] Pumped [X] Poured
Type: 3/8" WASHED PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 25 to 55 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1653
Signed (By driller performing actual drilling on site or contractor)
Date 3/6/2013

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED 2013 MAR 18 AM 11:5 STATE ENGINEER'S OFFICE