STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118333
Permit No.
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68496

1. OWNER Louis Kelly
MAILING ADDRESS 5740 Bird Lane Winnemucca NV.
ADDRESS AT WELL LOCATION 6665 Riverview Cn. Winnemucca NV.
Subdivision Name: Riverview Estates County: Humboldt

2. LOCATION NW¼ SE ¼ Sec 34 T 36 N/S R 37 E
PERMIT/WAIVER No. 010-697-02 Issued by Water Resources Parcel No.
Latitude N 40°57.197 Longitude W 117°48.088
UTM E N
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard brown clay	NO	0	40	40
Coarse gravel/Sand	Yes	40	200	160

Date started: 4-2, 20 13
Date completed: 4-5, 20 13

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 195 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 7/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	15
6 5/8	PVC	Sched. 40	15	195

Perforations:
Type of perforation Slot
Size of perforation .20
From 155 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 200 ☐ Pumped ☒ Poured
Type: 3/8" Pea Gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 38 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	NA	3

NAD 40.953283°N
117.801467°W

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. Contractor
Address 5140 Jungo Rd. Contractor
Winnemucca NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 76278
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed By driller performing actual drilling on-site or contractor
Date 4-15-13

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

(O) 627