STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 1183338
Permit No. 82548T
Basin 137B

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70039

1. OWNER Round Mountain Gold Corp. DW-66
MAILING ADDRESS P.O. Box 480
Round Mountain, NV. 89045

ADDRESS AT WELL LOCATION Round Mountain Pit
Round Mountain, NV.
Subdivision Name: County: Nye

2. LOCATION SE¼SW¼ Sec19T10N/ R44E
PERMIT/WAIVER NO. 82548-T (Issued by Water Resources) R3D-13-03 (Parcel. No.)

Latitude
Longitude
UTM E 492841 ☒ NAD 27
N 4283853 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Flooded Rev

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Poorly Welded Tuff		0	230	230
Paleozoic Meta Sediments		230	840	610

DW-66

9. WELL CONSTRUCTION

Depth Drilled 840 Feet Depth Cased 820 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
26 Inches	0 Feet	40 Feet
19 Inches	40 Feet	840 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
22	86.60	.375	0	40
12.75	33.38	.250	+2	820
2.375	3.65	.145	+2	780

Perforations:
Type of perforation Louvered
Size of perforation .125
From 180 feet to 780 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 150 to 840 ☐ Pumped ☒ Poured
Type: 3/4 x 1/2 SRI
Bentonite Chips: ☒ Yes ☐ No 50 to 150 ☒ Pumped ☐ Poured
Type: 3/8 Hole Plug

Date started: March 17, 20 13
Date completed: April 2, 20 13

7. Water Level
Static water level: 136 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Warm °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
120	N/A	1

NAD 27
38.705137°N
117.082321°W

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)
Address 2745 California Ave. (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2350
Signed
By driller performing actual drilling on site or contractor
Date April 12, 2013