STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118343
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70261

1. OWNER ARNOLD BECK CONSTRUCTION INC
MAILING ADDRESS 247 GREENCREST DR
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION 1134 DRY CREEK TRAIL
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION SE ¼ NW ¼ Sec 33 T 34N N/S R 55 E
PERMIT/WAIVER No. 006-09Q-023
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0602230 [X] NAD 27
N 4516016 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL STRIPPED				
GRAVEL w/ BOULDERS		0	8	8
GRAVEL w/ CLAY		8	50	42
GREY GREEN SAND & CLAY		50	60	10
THICK GREY BLACK CLAY	X	60	295	235
GREY BROWN VOLCANIC TUFT	XXX	295	320	25
1ST WATER X	275			
2ND WATER XXX	300			

Date started: 2-Apr , 20 13
Date completed: 3-Apr , 20 13

9. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	inches	0	Feet	320	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	320

Perforations:
Type of perforation PLASMA CUT
Size of perforation 3/16" X 4", 7 ROWS
From 300 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 4 to 25 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 55 to 320 [ ] Pumped [X] Poured
Type: 3/8" WASHED PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 25 to 55 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 105 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 72 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AT 320'	60		1 1/2 HOURS
AT 220'	50		
AT 180'	20		
AT 160'	10		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1653
Signed (By driller performing actual drilling on site or contractor)
Date 4/5/2013

(Rev. 05-08)
USE ADDITIONAL SHEETS IF NECESSARY

NAD27 40.790854°N, 115.788317°W