STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118346
Permit No.
Basin 106

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63292

1. OWNER Joe Scaliase
MAILING ADDRESS 1875 Hwy 395 South
Topaz NV
ADDRESS AT WELL LOCATION 1875 Hwy 395 S
Subdivision Name: Douglas County

2. LOCATION SW¼ NW¼ Sec 29 T 10 N/S R 22 E
PERMIT/WAIVER No. 1022.29.301.001 (Issued by Water Resources) Parcel No.
Latitude 38.702285°N Longitude 119.55136°W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand + rock		0	20	20
clay + chip rock		20	48	28
multi colored chip rock		48	118	70
brown clay + chip rock		118	172	54
hard chip rock		172	220	48
brown red clay		220	228	8
clay + chip rock		228	284	56
hard rock + orange clay		284	346	62
multi colored rock + DG		346	367	21
multi colored granite		367	463	96
large size granite		463	532	69
multi colored				

Date started: 03-08 , 20 13
Date completed: 03-20 , 20 13

9. WELL CONSTRUCTION
Depth Drilled 532 Feet Depth Cased 532 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	322	Feet
9 5/8	Inches	322	Feet	532	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	532

Perforations:
Type of perforation Factory
Size of perforation 3/32 x 4
From 512 feet to 532 feet
From 472 feet to 492 feet
From 372 feet to 392 feet
From 312 feet to 332 feet
From 212 feet to 232 feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☒ Cement Grout	0 to 106		☐ Pumped	☒ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 106 to 532 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: feet below land surface
Artesian Flow: n/A G.P.M. 7-10 P.S.I.
Water Temperature: Cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
530 FT	7-10		13

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Blair Drilling (Contractor)
Address PO Box 1255 CC NV 89702 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 46498A
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* ~~1321~~ 2134
Signed C. Robinson (By driller performing actual drilling on site or contractor)
Date 03-29-13

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

NAD27 38.702948°N
119.550358°W