STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118424
Permit No.
Basin 069

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68494

1. OWNER William Lambert
MAILING ADDRESS 3635 Lambert Dr. Winnemucca NV. 89445

ADDRESS AT WELL LOCATION 3635 Lambert Dr. Winnemucca NV. 89445
Subdivision Name: Lambert County: Humboldt

2. LOCATION NW¼ NW¼ Sec 22 T 37 N S R 38 E
PERMIT/WAIVER No. 006-401-35 Issued by Water Resources Parcel No.

Latitude N41° 04.542 Longitude W117° 41.699 UTM E N ☐ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
■ Deepen ☐ Other

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Existing Hole	NO	0	50	50
Existing Hole	Yes	50	60	10
Gravel Stand	Yes	60	100	40

* Original well log being deepened - UNKNOWN

Date started: 1-4, 20 13
Date completed: 1-6, 20 13

7. Water Level
Static water level: 50 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	NA	2

9. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 3/4 Inches	60 Feet	100 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	20
6 5/8	PVC	Sched 40	20	100

Perforations:
Type of perforation Slot
Size of perforation .020
From 60 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 50 ☐ Pumped ■ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ■ Yes ☐ No 50 to 100 ☐ Pumped ■ Poured
Type: 3/8" Pea
Bentonite Chips: ☐ Yes ■ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Allied Drilling Inc.
Address (Contractor) 5140 Jungo Rd. Winnemucca NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed (By driller performing actual drilling on-site or contractor)
Date 1-15-13

USE ADDITIONAL SHEETS IF NECESSARY

41.075700°N
117.694983°W NAD27

(Rev. 05-08)
(NSPO 3-08)
(O) 627

RECEIVED 2013 FEB -5 PM 12:55 STATE ENGINEERS OFFICE