

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 118479  
Permit No. \_\_\_\_\_  
Basin 162

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36268

1. OWNER GEORGE BRIZENDINE ADDRESS AT WELL LOCATION 1550 S RED ROCK DR  
MAILING ADDRESS 1550 S RED ROCK DR PAHRUMP NV  
PAHRUMP NV 89048-4964 Subdivision Name: UNIT 8B CALVADA VLY County: NYE

2. LOCATION NW 1/4 SW 1/4 Sec 21 T 20S N/S R 53 E Latitude N36°11'49.6" UTM E  NAD 27  
PERMIT/WAIVER No. 39-101-26 Longitude W116°01'40.1" N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  Domestic  
 Deepen  Other Replacement  Municipal/Industrial  
4. PROPOSED USE  
 Irrigation  Test  Cable  Rotary  RVC  
 Monitor  Stock  Air  Other

6. LITHOLOGIC LOG Well ?

Material	Water Strata	From	To	Thick-ness
CLAY		0	30	30
CALICHIE		30	38	8
CLAY		38	65	27
CALICHIE	WB	65	85	20
CLAY		85	100	15
CALICHIE	WB	100	110	10
CLAY		110	130	20
CALICHIE	WB	130	135	5
CLAY		135	175	40
CALICHIE	WB	175	195	20
CLAY		195	220	25
CALICHIE	WB	220	235	15
CLAY		235	260	25
CALICHIE	WB	260	285	25
CLAY		285	300	15

DCNR/DWR/SNBO RECEIVED  
OCT 10 2013  
See plug log # 118478

9. WELL CONSTRUCTION

Depth Drilled	300	Feet	Depth Cased	300	Feet
HOLE DIAMETER (BIT SIZE)					
	12	Inches	0	Feet	300
		Inches		Feet	
		Inches		Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	3.63	.280	0	300

Perforations:

Type of perforation	SCREEN
Size of perforation	.032
From	180 feet to 300 feet
From	feet to feet
From	feet to feet
From	feet to feet

Annular Seal:  Yes  No

<input type="checkbox"/> Neat Cement	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Concrete Grout	0 to 50	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack:  Yes  No 50 to 300  Pumped  Poured  
Type: CONCRETE  
Bentonite Chips:  Yes  No to  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 24-Aug, 20 13  
Date completed: 24-Aug, 20 13

7. Water Level  
Static water level: 75 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name GREAT BASIN DRILLING Contractor  
Address 1220 MANSE RD Contractor  
PAHRUMP NV 89048  
Nevada contractor's license number 47333  
issued by the State Contractor's Board  
Nevada driller's license number issued by the 2485  
Division of Water Resources, the on-site driller  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 8-Oct