STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116538
Permit No.
Basin 089

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66625

1. OWNER Jarrod Miller
MAILING ADDRESS 4015 Drake washoe vally NE SN
ADDRESS AT WELL LOCATION 4015 Drake Washoe
Subdivision Name: County:

2. LOCATION NW ¼ SE ¼ Sec 32 T 17 N/S R 20 E
PERMIT/WAIVER No. DOM13-621 050-304-09
Issued by Water Resources Parcel No.
Latitude 39°17.671 Longitude 119°45.728
UTM E N ☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt		0	6	6
Clay		6	11	5
Sand with Gritty Clay		11	18	7
Black Chip Rock &		15	x	
Sand		x	68	50
DG		68	140	72
Large Sand and Clay		140	202	62
Granite Brown		202	243	41
Brown Dense Clay		243	271	28
~~Brown Granite~~				
Brown Sand stone		271	280	11
loos Large Sand		280	295	15
Brown Granite		295	315	20
Grey Granite		315	375	60

RECEIVED 2013 NOV 12 PM 2:52 STATE ENGINEERS OFFICE

Date started: 9-11-13, 20
Date completed: 9-19-13, 20

9. WELL CONSTRUCTION
Depth Drilled 375 Feet Depth Cased 375 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	75	Feet
9 7/8	Inches	75	Feet	265	Feet
8 3/4	Inches	265	Feet	375	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	375

Perforations:
Type of perforation Factory
Size of perforation 3/32
From 255 feet to 275 feet
From ~~345~~ 325 feet to 345 feet
From 355 feet to 375 feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout ~~56~~ to ~~375~~ ☐ Pumped ☒ Poured
☐ Concrete Grout 0 to 56 ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 56 to 375 ☐ Pumped ☐ Poured
Type: 3/8 Round
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 150 feet below land surface
Artesian Flow: N/A G.P.M. 20+ P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
325	20+		3
Replaces well log 26252			
NAD27	39.2946060 N		
	119.7611160 W		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BLAIN DRILLING & PUMP CO INC.
Contractor
Address P.O. Box 1255
Carson City, NV 89702
Contractor

Nevada contractor's license number issued by the State Contractor's Board 46498A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2321

Signed C. Robinson
By driller performing actual drilling on-site or contractor
Date 9-20-13

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627