STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118392
Permit No. 83116
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70720

1. OWNER ARTISAN EAST LLC
MAILING ADDRESS 4940 LEO BINGO CT
WASHOE VALLEY, NV 89704

ADDRESS AT WELL LOCATION 437 MACY CT
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION SE ¼ NW ¼ Sec 28 T 34N N/S R 55 E
PERMIT/WAIVER No. 83116 (Issued by Water Resources) 006-09P-161 (Parcel No.)

Latitude
Longitude
UTM E 11T 0602476 [X] NAD 27
N 4517750 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL w/ GRAVEL		0	10	10
TAN CLAY		10	60	50
GRAY CLAY		60	180	120
GRAY CLAY & SANDSTONE	X	180	240	60
FIRST WATER	80			

RECEIVED
2013 NOV 15 AM 11:13
STATE ENGINEERS OFFICE

Date started: 7-Nov, 20 13
Date completed: 8-Nov, 20 13

7. *Water Level*
Static water level: 53 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 70 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AT 235'	70+		1 HOUR
AT 140'	50		5 MIN
AT 120'	35		5 MIN
NAD27			
40.806270 N			
115.745117			

9. *WELL CONSTRUCTION*
Depth Drilled 240 Feet Depth Cased 238 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	238

Perforations:
Type of perforation PLASMA CUT
Size of perforation 3/16" X 4" 7 ROWS
From 218 feet to 238 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 4 to 105 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 105 to 240 [ ] Pumped [X] Poured
Type: 3/8" WASHED PEA GRAVEL
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1166
Signed Dale C. Veden (By driller performing actual drilling on site or contractor)
Date 11/11/2013

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY