

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 118559
Permit No. _____
Basin 207

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68396
280 N MAIN Hwy 318
Subdivision Name: _____ County: _____

1 OWNER Kristopher Jackson
MAILING ADDRESS P.O. Box 272
Land, NV 89317
2 LOCATION NW NE 1/4 Sec 33 T 12 N S R 62 E
PERMIT/WAIVER No. R-745 | 006-01-507
Issued by Water Resources Parcel No.

ADDRESS AT WELL LOCATION
Latitude 38° 51.827' UTM E _____ NAD 27
Longitude 115° 00.440' N _____ NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? no
Is there an existing well log? no
If yes, what is NDWR well log #? _____

4 Hand dug EXISTING WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased not cased Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Was the well contaminated? yes no
Was the casing pulled? yes no no casing
Was the casing over drilled? yes no

Existing Perforations:
Type of perforation not cased
Size of perforation _____
From _____ feet to _____ feet
From _____ feet to _____ feet

If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used:
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____

5 WATER LEVEL
Static water level 44' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

6 Additional Notes or Comments
This was a hand dug well
3.5' diameter 45' total depth
the well had a cinder block-concrete enclosure, starting 3' above ground and extending 2' below ground surface. it had a metal plate fastened to the top-to seal the well
Clean Fill material was settled and compacted as added to prevent further settling, when the 2' level was reached the cinder block concrete structure was removed, and the filling completed
plug unknown well log
STATE ENGINEERS OF NEVADA
15,00649.40
NOV 20 AM 11:00
RECEIVED

From	feet to	Material Used	Pumped	Poured
From <u>45</u>	feet to <u>41</u>	feet <u>Bentonite Chips</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
From <u>41</u>	feet to <u>39</u>	feet <u>concrete grade</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
From _____	feet to _____	feet _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From <u>39</u>	feet to <u>0</u>	feet <u>Clean Fill</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
From _____	feet to _____	feet _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From _____	feet to _____	feet _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Neat Cement Fluid Weight _____ lbs/gal
Bentonite Grout _____ % bentonite
Date Started Oct 25 -13
Date Completed Oct 28 -13

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Maynard Well Drilling Contractor
Address Box 64 Land, NV 89317 Contractor
Nevada contractor's license number issued by the State Contractor's Board 047226
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Maynard By driller performing actual drilling per site or contractor
Date Nov 18-13

USE ADDITIONAL SHEETS IF NECESSARY