ong

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118566
Permit No.
Basin 173B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70911

1. OWNER Dave Weaver
MAILING ADDRESS 1405 Mill Street Ely Nev 89301
ADDRESS AT WELL LOCATION Angleworm Ranch Road Currant NV
Subdivision Name: ⊖ County: NYE

2. LOCATION NE ¼ SE ¼ Sec 31 T 11 N/S R 58 E
PERMIT/WAIVER No. ⊖ 13-291-10
Issued by Water Resources Parcel No.
Latitude N 38°45.918 UTM E ☐ NAD 27
Longitude W115 29.258 N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand-Boulders		0	80	80
Fractured Rock	X	80	305	225

RECEIVED 2013 NOV 21 AM 10:50 STATE ENGINEERS OFFICE

NAD27
38.765365° N
115.456711° W

Date started: 10-1-2013, 20
Date completed: 10-20-2013, 20

7. Water Level
Static water level: 226 feet below land surface
Artesian Flow: ⊖ G.P.M. P.S.I.
Water Temperature: calc °F
Quality: good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8		2

9. WELL CONSTRUCTION
Depth Drilled 305 Feet Depth Cased 305 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
13	Inches	0	Feet	305	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	steel	.188	0	305

Perforations:
Type of perforation Factory
Size of perforation 1/8" X 3"
From 165 feet to 185 feet
From 205 feet to 305 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 50 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 305 ☐ Pumped ☒ Poured
Type: 1/4" minus
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 Hiko NV 89017 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Dai
By driller performing actual drilling on-site or contractor
Date 10-20-2013

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

(O) 627