corrected

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118586
Permit No.
Basin 029

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70755

1. OWNER Dennis Woodward
MAILING ADDRESS 432 W. 5th St. Apt 3
Winnemucca NV. 89445

ADDRESS AT WELL LOCATION 29250 Woodward Rd.
Winnemucca NV.
Subdivision Name: County: Humboldt

2. LOCATION NE ¼ SE ¼ Sec 11 T 43 N S R 30 E
PERMIT/WAIVER No. 002-371-03
Issued by Water Resources Parcel No.

Latitude N41°36.786
Longitude W118°35.081
UTM E N
■ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay Sand Boulders	NO	0	15	15
Clay Sand Gravel	NO	15	60	45
Clay	NO	60	65	5
Clay Gravel Sand boulders	YES	65	160	95

NAD27
41.613100°N
118.584683°W

Date started: 10-23, 20 13
Date completed: 10-24, 20 13

RECEIVED 2013 NOV 25 PM 2:01 STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 7/8	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 7/8	Steel	.188	0	20
6 7/8	PVC	Sched 40	20	160

Perforations:
Type of perforation Slot
Size of perforation .20
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 30 ☐ Pumped ■ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
■ ≥30% Bentonite Grout 70 to 100 ■ Pumped ☐ Poured
Gravel Pack: ■ Yes ☐ No 100 to 160 ☐ Pumped ■ Poured
Type: 3/8" Pea
Bentonite Chips: ■ Yes ☐ No 30 to 70 ☐ Pumped ■ Poured
Type: 3/8" chip

7. Water Level
Static water level: 70 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	NA	2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc.
Contractor
Address 5140 Jungo Rd.
Contractor
Winnemucca NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 10-24-13

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-05)

(NSPO 3-08)

(O) 627