

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY  
Log No. 118600  
Permit No. \_\_\_\_\_  
Basin 007

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69801

1 OWNER Atlantic Richfield Company  
MAILING ADDRESS 6 Centerpointe Drive LPR6-161, La Palma, CA 9

ADDRESS AT WELL LOCATION 700 Keystone Ave  
Subdivision Name: \_\_\_\_\_ County: Washoe

2 LOCATION NE ¼ NE ¼ Sec 10 T 19N N/S R 19 E  
PERMIT/WAIVER No. 4-000017 006-121-27  
Issued by Water Resources Parcel No. \_\_\_\_\_

Latitude 39 31' 52.02"N UTM E  NAD 27  
Longitude 119 49' 50.99" N  NAD 83/WGS 84

3 TYPE OF WELL  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

Is this well being plugged because a replacement well was drilled? NO  
If yes, what is replacement well NO#? \_\_\_\_\_

Is there an existing well log? NO  
If yes, what is NDWR well log #? \_\_\_\_\_

4 EXISTING WELL CONSTRUCTION  
Depth Drilled 90 Feet Depth Cased 90 Feet

| EXISTING CASING SCHEDULE |                     |                         |             |           |
|--------------------------|---------------------|-------------------------|-------------|-----------|
| Size O.D. (Inches)       | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
| 2"                       | .682 lbs/ft         | .154                    | 90          | 0         |
|                          |                     |                         |             |           |
|                          |                     |                         |             |           |

Existing Perforations:

| Type of perforation                   | Machine Slot        |
|---------------------------------------|---------------------|
| From <u>90</u> feet to <u>85</u> feet | <u>unknown .620</u> |
| From _____ feet to _____ feet         | _____               |
| From _____ feet to _____ feet         | _____               |
| From _____ feet to _____ feet         | _____               |
| From _____ feet to _____ feet         | _____               |

5 WATER LEVEL  
Static water level 75 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
Water temperature \_\_\_\_\_ ° F Quality \_\_\_\_\_

6 Additional Notes or Comments  
2" sch 40 PVC casing  
0.020" slot hole screen  
pumped volume of neat cement  
# silica sand 28.64 gal.

15- plug withdrawn well log

RECEIVED  
2013 DEC -2 PM 1:17  
STATE ENGINEERS OFFICE  
NAD 27  
39.53221 N  
119.829827 W

7 WELL PLUGGING PROCEDURE  
Was well cleaned out to total depth?  yes  no  
If well was not cleaned out to total depth, please explain why: \_\_\_\_\_

Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no  
If casing was left in place, please show where additional perforations were made:  
Additional Perforations:  
Type of perforator used:  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perfs per linear foot \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perfs per linear foot \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perfs per linear foot \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perfs per linear foot \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perfs per linear foot \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perfs per linear foot \_\_\_\_\_

8 WELL PLUGGING MATERIALS

| From           | feet to          | Material Used | <input type="checkbox"/> Pumped     | <input type="checkbox"/> Poured     |
|----------------|------------------|---------------|-------------------------------------|-------------------------------------|
| From <u>90</u> | feet to <u>3</u> | Neat Cement   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| From <u>3</u>  | feet to <u>1</u> | Fill          | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| From <u>1</u>  | feet to <u>0</u> | Concrete Cap  | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| From _____     | feet to _____    | _____         | <input type="checkbox"/>            | <input type="checkbox"/>            |
| From _____     | feet to _____    | _____         | <input type="checkbox"/>            | <input type="checkbox"/>            |
| From _____     | feet to _____    | _____         | <input type="checkbox"/>            | <input type="checkbox"/>            |

Neat Cement Fluid Weight 14.8 lbs/gal  
Bentonite Grout 2 % bentonite  
Date Started 9/17/2013  
Date Completed 9/17/2013

9 DRILLER'S CERTIFICATION  
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.  
Name \_\_\_\_\_ National EWP Contractor  
Address 2086 E. Main Street, Woodland, CA 95776 Contractor  
Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 0075355  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2466-M  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 11/22/2013

(Rev. 06-05)

USE ADDITIONAL SHEETS IF NECESSARY