

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 119613  
Permit No. \_\_\_\_\_  
Basin 057

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68408

1. OWNER Mario Bullentini ADDRESS AT WELL LOCATION 255 Brunswick Mill Rd  
MAILING ADDRESS 255 Brunswick Mill Rd Reno, NV 89511

2. LOCATION NVA 1/4 NE 1/4 Sec 11 T 18N N/S R 19 E Latitude 39.44096 UTM E  NAD 27  
PERMIT/WAIVER No. SW 13-64 041-211-06 Longitude 119.82270 N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name: \_\_\_\_\_ County: Washoe

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other...  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other... Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & 1/2" gravel	x	302	345	43
Sandy clay	x	345	360	15
Course sand	x	360	367	7
Hard rock		367	407	40
Sandy clay	x	407	443	36
Hard rock		443	467	24
Sandy clay	x	467	495	28
Hard rock		495	500	5
Sandy clay	x	500	525	25
Hard rock		525	563	38
Fractured rock	x	563	575	12
Sandy clay	x	575	585	10
Hard rock		585	590	5

RECEIVED  
2013 NOV -6 AM 11:14  
STATE ENGINEERS OFFICE

*deeper well log  
78734*

*NAD 27  
S 24 W 121 9 0 N  
119.82210 10 10 0 W*

8. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
590		590	

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
6 1/8	302	590	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 9/16	10.7	188	290	590

Perforations:

Type of perforation	mill slot
Size of perforation	3/32
From 310	feet to 370
From 410	feet to 430
From 450	feet to 470
From 490	feet to 510
From 550	feet to 590

Surface Seal:  Yes  No  
Depth of Seal in place  
Placement Method:  Pumped  Poured  
Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

9. WATER LEVEL  
Static water level 46 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality unknown

Date started 6-Nov, 20 13  
Date completed 15-Nov, 20 13

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	20	79	
	30	154	7 1/2
	30	254	
	40	529	

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name McKay Drilling, Inc. Contractor  
Address 4850 Joule St A-5 Contractor  
Reno, NV 89502  
Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 14170  
Nevada driller's license number issued by the \_\_\_\_\_  
Division of Water Resources, the on-site driller 2121  
Signed Steve McKay  
By driller performing actual drilling on site or contractor  
Date 12/04/2013