

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY
Log No. 118635
Permit No. _____
Basin 105

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 69882

1 OWNER Jeff Wass
MAILING ADDRESS Gardnerville, NV. 89410

ADDRESS AT WELL LOCATION just off Sierra Country Circle in
Sierra Country Estates in Douglas County
Subdivision Name: _____ County: Douglas

2 LOCATION NW 1/4 SW 1/4 Sec 10 T 20N N/S R 19 E
PERMIT/WAIVER No. 1219-10-002-062
Issued by Water Resources Parcel No.

Latitude 38d 54.899 N N UTM E _____ NAD 27
Longitude 119d 50.515 W W N _____ NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? no
Is there an existing well log? no
If yes, what is replacement well NO? _____
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION

Depth Drilled n/a Feet Depth Cased 76 Feet

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12		.250	0	76

7 WELL PLUGGING PROCEDURE

Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:

Type of perforation	Size of perforation	From	To
<u>Assume</u>	<u>50</u>	<u>feet to</u>	<u>feet</u>

If casing was left in place, please show where additional perforations were made:
Additional Perforations:

Type of perforator used:	Mills Knife
From <u>50</u> feet to <u>surface</u> feet	Number of perfs per linear foot <u>6</u>
From _____ feet to _____ feet	Number of perfs per linear foot _____
From _____ feet to _____ feet	Number of perfs per linear foot _____
From _____ feet to _____ feet	Number of perfs per linear foot _____
From _____ feet to _____ feet	Number of perfs per linear foot _____
From _____ feet to _____ feet	Number of perfs per linear foot _____

5 WATER LEVEL

Static water level 2.8' feet below land surface
Artesian flow _____ G.P.M. P.S.I.
Water temperature _____ ° F Quality _____

8 WELL PLUGGING MATERIALS

From	feet to	Material Used	
From <u>76</u>	feet to <u>surface</u>	neat cement	<input checked="" type="checkbox"/> Pumped <input type="checkbox"/> Poured
From _____	feet to _____		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
From _____	feet to _____		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
From _____	feet to _____		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
From _____	feet to _____		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
From _____	feet to _____		<input type="checkbox"/> Pumped <input type="checkbox"/> Poured

6 Additional Notes or Comments

Measured depth of well at 70'. Bailed debris until we hit a hard bottom at 76'. Installed 12" Mills Knife and perforated from 50' to surface at 6 rows per foot. Removed perforator and installed 73' of 2" tremme pipe. The following day we mixed 60 bags of Portland II cement with approx. 300 gallons of water and pumped in from bottom of well to surface. The next day, we sounded cement at 17' bgs. We then mixed 14 bags of with 70 gallons of water and topped well off.

Neat Cement Fluid Weight 14.3 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 11/22/2013
Date Completed 11/25/2013

RECEIVED
2013 DEC 10 AM 11:09
STATE ENGINEERS OFFICE
plus unknown well log
NAD 27
38.915096 N
119.840905 W

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name Carson Pump, LLC Contractor
Address P.O. Box 20159 Contractor
Carson City, NV. 89721

Nevada contractor's license number _____
issued by the State Contractor's Board 39920A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2265

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 12/4/2013