STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118640
Permit No.
Basin 207

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67914

1. OWNER Mike Davis
MAILING ADDRESS HC 61 Box 54
Hiko NV 89017

ADDRESS AT WELL LOCATION Forest Moon Ranch
Sunnyside NV
Subdivision Name: Forest Moon Ranch County: NYE

2. LOCATION NW/4 SE ¼ Sec 13 T 6 N/S R 60 E
PERMIT/WAIVER No. 0 (Issued by Water Resources) 013-801-01 Parcel No.

Latitude N38°22.644 Longitude W115°10.802
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay-sand boulders	X	0	110	110
Clay-sand	X	110	115	5
Hard Clay		115	120	5

RECEIVED 2013 JAN 10 AM 11:37 STATE ENGINEERS OFFICE

Date started: 1-4-2013 , 20
Date completed: 1-4-2013 , 20

7. Water Level
Static water level: 13 feet below land surface
Artesian Flow: 0 G.P.M. P.S.I.
Water Temperature: cold °F
Quality: fair

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
22		2

NAD 27
38.377451° N
115.179182° W

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 1/2	PVC	Sch 40	0	120

Perforations:
Type of perforation Saw cut
Size of perforation 1/8" x 3"
From 60 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 120 ☐ Pumped ☒ Poured
Type: 1/4" Minus
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Davis Drilling and Pumps
Address (Contractor) HC 61 Box 54
Hiko NV 89017
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis
By driller performing actual drilling on-site or contractor
Date 1-5-2013

(Rev. 06-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627