STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 486656
Permit No.
Basin 070

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68257

1. OWNER Vernon F & Karen Anderson
MAILING ADDRESS 4995 Airview Blvd Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 4995 Airview Blvd
Winnemucca, NV
Subdivision Name: Airport Estates #3 County: humboldt

2. LOCATION NW¼SW ¼ Sec23T35N/ R37E
PERMIT/WAIVER NO. N/A Issued by Water Resources
014-091-01 Parcel. No.

Latitude N40°53.501 Longitude W117°47.608
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Silt		115	120	5
Fine Gravel		120	145	25
Clay		145	165	20
Gravel/Sand	X	165	200	35
Clay		200	210	10

Deepens unknown log number

RECEIVED 2012 AUG 30 AM 10:20 STATE ENGINEER'S OFFICE

Date started: Aug 3, 20 12
Date completed: Aug 3, 20 12

7. Water Level
Static water level: 68 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20-25		3
	40.891780°N	NAD 27
	117.792502°W	

9. WELL CONSTRUCTION
Depth Drilled 115-210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7 1/2 Inches	115 Feet	210 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	.188	110	210

Perforations:
Type of perforation factory Cut
Size of perforation 3/32 x 4
From 170 feet to 210 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No

	Existing	to		
☐ Neat Cement			☐ Pumped	☐ Poured
☐ Cement Grout			☐ Pumped	☐ Poured
☐ Concrete Grout			☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout			☐ Pumped	☐ Poured

Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed 8-24-12

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-8429 · FormsOnADisk.com