STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118661
Permit No.
Basin 129

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68488

1. OWNER Pat Gray
MAILING ADDRESS 1099 W. Wman Blvd. Winnemucca NV.
ADDRESS AT WELL LOCATION 2605 W. Unionville Rd. Unionville NV.
Subdivision Name: County: Pershing

2. LOCATION NE ¼ NE ¼ Sec 26 T 30 N S R 34 E
PERMIT/WAIVER No. 012-030-10
Issued by Water Resources Parcel No.
Latitude N40°26.778
Longitude W118°07.138
UTM E N
■ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel Boulders	NO	0	40	40
Gravel Boulders	Yes	40	130	90

RECEIVED 2013 DEC 13 AM 11:34 STATE ENGINEERS OFFICE

NAD27
40.446317°N
118.116967°W

Date started: 12-10, 20 12
Date completed: 1-25, 20 13

9. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 7/8	Inches	0	Feet	130	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	20
6 5/8	PVC	Sched 40	20	130

Perforations:
Type of perforation slot
Size of perforation .02
From 110 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 100 ■ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ■ Yes ☐ No 100 to 130 ☐ Pumped ■ Poured
Type: 3/8" Pea
Bentonite Chips: ☐ Yes ■ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 50 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5	NA	4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc.
Contractor
Address 5140 Jungo Rd.
Contractor
Winnemucca NV.
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 2-15-13

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627