STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 1186164
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70145

1. OWNER Nicholas Richard
MAILING ADDRESS 1270 S. Bridge St.
S. Winnemucca NV
ADDRESS AT WELL LOCATION 9355 Sabin Dr.
Winnemucca NV
Subdivision Name: Canyon Run County: Humboldt

2. LOCATION NE NE ¼ Sec 30 T 35 N/S R 38 E/W
Latitude N 40° 53.004 Longitude W 117° 44.290
UTM E N NAD 27 NAD 83/WGS 84
PERMIT/WAIVER No. 010-645-12 (Issued by Water Resources) Parcel No.

3. WORKED PERFORMED: ■ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE: ■ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ■ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand	NO	0	2	2
Coarse Gravel Boulders	NO	2	160	158
Cemented Gravel Clay	NO	158	320	162
Cemented Gravel Clay	Yes	320	400	80

NAD27
40.9833 400N
117.7338 1670W

Date started: 8-27 20 13
Date completed: 8-31 20 13

7. Water Level
Static water level: 307 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	NA	4

9. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	400 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	20
6 5/8	PVC	Sched. 40	20	400

Perforations:
Type of perforation Slot
Size of perforation .20
From 300 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 50 ☐ Pumped ■ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ■ Yes ☐ No 50 to 400 ☐ Pumped ■ Poured
Type: 3/8" pea
Bentonite Chips: ☐ Yes ■ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Jungo Rd. (Contractor)
Winnemucca NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 76278
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed (By driller performing actual drilling on-site or contractor)
Date 9-3-13

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627