

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118680
Permit No. _____
Basin 228

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37512
01555 Valley Basin

1. OWNER CORIKIS Gold Nevada, Inc
MAILING ADDRESS 9137 RHOBELENE BLVD #250
HIGHLANDS Ranch, Colorado 80129

ADDRESS AT WELL LOCATION
Subdivision Name: _____ County: NYE

2. LOCATION NE 1/4 NW 1/4 Sec 37 T 10 N R 46 E
PERMIT/WAIVER No. MO-2967

Latitude _____ UTM E 516410.0 NAD 27
Longitude _____ N 4097780.0 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>GRAVEL</u>	<u>NO</u>	<u>0</u>	<u>20'</u>	<u>20'</u>
<u>CLAY / Gravel</u>		<u>20'</u>	<u>50'</u>	<u>30'</u>
<u>Hardrock Blk / Gray</u>		<u>50'</u>	<u>135'</u>	<u>85'</u>
<u>Blk / Gray Volcanics</u>		<u>135'</u>	<u>445'</u>	<u>310'</u>

9. WELL CONSTRUCTION

Depth Drilled 445' Feet Depth Cased 445' Feet

HOLE DIAMETER (BIT SIZE)

	From	To	Feet	Feet
<u>14 3/4"</u> inches	<u>0'</u>	<u>20'</u>		
<u>8 3/4"</u> inches	<u>20'</u>	<u>445'</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>		<u>1/4"</u>	<u>+18</u>	<u>445'</u>

RECEIVED
2013 NOV 12 PM 12:58
STATE ENGINEERS OFFICE

DGNR DWR/SNBC
RECEIVED
NOV 14 2013

Perforations:
Type of perforation Tooth Cut
Size of perforation 1/8" ID

From 345' feet to 445' feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement 0' to 20' Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 343' to 445' Pumped Poured
Type: _____

Bentonite Chips: Yes No _____ to _____ Pumped Poured
Type: _____

Date started: August 22nd 20 13
Date completed: August 25th 20 13

7. Water Level
Static water level: 289.3 feet below land surface
Artesian Flow: NO G.P.M. 3 P.S.I.
Water Temperature: 81.1 °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>3</u>		<u>1 Hr</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Boart Longyear Nevada
Contractor

Address PO Box 2748
Contractor

Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0073086

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2426

Signed Josh McManus
By driller performing actual drilling on site or contractor

Date 8-25-13

37.0297022 NAD 27
-116.8155011

37.0297466 NAD 83
-116.8146048