STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118724
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37531

1. OWNER Urban Land Nevada
MAILING ADDRESS 3271 S. Highland Dr. #714
Las Vegas NV 89109

ADDRESS AT WELL LOCATION 4581 East Charleston Blvd.
Las Vegas NV
Subdivision Name: County: Clark

2. LOCATION NE ¼ NW ¼ Sec 5 T 21S N/S R 62 E
PERMIT/WAIVER No. 161-05-115-008
Issued by Water Resources Parcel No.

Latitude 36 09' 31.55
Longitude 115 04 29.36
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Asphalt | | 0 | 1 | 1 |
| Clay | x | 1 | 20 | 19 |

DCNR/DWR/SNBO
RECEIVED
FEB 22 2013

Date started: 2-11- , 20 13
Date completed: 2-12 , 20 13

7. Water Level
Static water level: 8.5 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | 0 | |

9. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 1/4 Inches | | 0 Feet | 20 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.5" | SCH40PVC | .188 | 0 | 10 |

Perforations:
Type of perforation Factory
Size of perforation .020
From 10 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0' to 2' ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 8 to 20 ☐ Pumped ☒ Poured
Type: #08
Bentonite Chips: ☒ Yes ☐ No 2 to 8 ☐ Pumped ☒ Poured
Type: Hole plug 3/8" chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name National EWP
Contractor
Address 5566 Arrow Hwy Montclair Ca 91763
Contractor
0075355
Nevada contractor's license number
issued by the State Contractor's Board 0075355
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2492
Signed
By driller performing actual drilling on-site or contractor
Date 2-16-13

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

36.1587918
-115.07399
NAD 27

(NSPO 3-08)

(O) 627