STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118730
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37527

1. OWNER Charlie Brown Construction, Inc. / Cloud Commercial LLC
MAILING ADDRESS 908 SHARP CIRCLE
North Las Vegas NV 89030

ADDRESS AT WELL LOCATION 908 SHARP CIRCLE
North Las Vegas, NV 89030
Subdivision Name: County: CLARK

2. LOCATION SE ¼ SW ¼ Sec 11 T 20 N/S R 61 E
PERMIT/WAIVER No. 1391141 3017
Issued by Water Resources Parcel No.

Latitude 36.2199
Longitude 115.1294
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL	●	0	3	3'
CLAY	x	3	70	67

DCNR/DWR/SNBO
RECEIVED
FEB 22 2013

Date started: 02-01, 20 13
Date completed: 02-04, 20 13

9. WELL CONSTRUCTION
Depth Drilled 70 Feet Depth Cased 70 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/4	Inches	0	Feet	70	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5"	SCH 40 PVC	.188	0	30

Perforations:
Type of perforation FACTORY
Size of perforation .020
From 30 feet to 70 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 34 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 38 to 70 ☐ Pumped ☒ Poured
Type: #08 GRAVEL
Bentonite Chips: ☒ Yes ☐ No 34 to 38 ☐ Pumped ☒ Poured
Type: 3/8" CHIPS

7. Water Level
Static water level: 48.50 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality: CLEAR

8. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	Ø	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name National EWP
Contractor
Address 5566 Arrow Hwy Montclair CA 91763
Contractor

Nevada contractor's license number issued by the State Contractor's Board 0075355
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2492

Signed
By driller performing actual drilling on-site or contractor
Date 02-04-13

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

36.2199305 NAD 27
-115.1285644

(NSPO 3-08) (O) 627