STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118743
Permit No.
Basin No. 058

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 671666
WELL NAME (if applicable): MW-4

1. OWNER/CLIENT NAME McGinley & Associates
MAILING ADDRESS Sterling-UN Reno LLC
3411 Richmond St. Ste 200 Houston

DETAILED ADDRESS AT WELL LOCATION 2399 Valley Rd
Reno, NV 89512
Subdivision Name: County: Washoe

2. PLS LOCATION SE ¼ SE ¼ 35 Sec 20 N/S 19 E
PERMIT/WAIVER NO. 003-363-05
Issued by Water Resources Current Parcel No.

Latitude 39.5505067N UTM E ☐ NAD 27
Longitude 119.81041W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Gravel & sand			0	5'	
clay w/gravels			5'	25'	
sand & clay			25'	35'	
clay w/gravels			35'	55'	
gravels			55'	57'	

RECEIVED
2013 DEC 23 PM 1:24
STATE ENGINEERS OFFICE

NAD27
39.5505960N
119.8093859W

Plugged by Well log 126839

Date started: 10-23-13, 20
Date completed: 10-23-13, 20

9. WELL CONSTRUCTION
Depth Drilled: 57' Feet Depth Cased: ~~5'~~ 56 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10"	Inches	0	Feet	5'	Feet
8"	Inches	5'	Feet	57'	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		sch 40 screen 020	56'	26'
2"		blank sch 40	26'	0'

PERFORATIONS:
Type of perforation: Factory
Size of perforation: .020
From 26' Feet To 56' Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☐ Sanitary Seal		to		
☒ Neat Cement	22'	to 1'	☐ Pumped	☒ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ Bentonite Chips	24'	to 22'	☐ Pumped	☒ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	57'	to 24'	☐ Pumped	☒ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 31' Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Cascade Drilling
Contractor
Address 3000 Duluth St. West Sacramento CA 95691
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 739666
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2079

Signed: [signature]
By driller performing actual drilling on site or contractor
Date: 10-29-13

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY