STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118807
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37128

1. OWNER Dewey Strip Holdings L.L.C.
MAILING ADDRESS 9440 W. Sahara Ave.# 240
Las Vegas Nv. 89117-8821

ADDRESS AT WELL LOCATION 4207 S. Las Vegas Blvd.
Las Vegas Nv. 89119

2. LOCATION SW ¼ SW ¼ Sec 28 T 21S N/S R 61 E
PERMIT/WAIVER No. 162-28-401-001
Issued by Water Resources Parcel No.

Latitude 36.089509
Longitude -115.172017
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: *County:* Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	.3	0
Type 2		.3	.6	0
Sand W/Gravel		.6	3.5	3
Calichie		3.5	5.0	2
Gravel W/Sandy Clay		5.0	8.0	3
Calichie		8.0	10.5	3
LT.Sandy Clay		10.5	15.5	5
Calichie		15.5	17.0	2
Sand W/Gravel		17.0	23.0	6
Calichie		23.0	24.0	1
Clay,Sand,W/Gravel		24.0	27.0	3
Sand Clay		27.0	37.0	10
PMP-1-36				

DCNR/DWR/SNBO
RECEIVED
DEC 04 2013

Date started 10/25/2013 , 20 13
Date completed 10/25/2013 , 20 13

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 37 Feet Depth Cased 36 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6.5/8	Inches	0	Feet	37	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Factory	Machine	-5"	36

Perforations:
Type of perforation Machine
Size of perforation 0.02
From 31 feet to 36 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 20
Placement Method: ☐ Pumped ☑ Poured
Gravel Packed: ☑ Yes ☐ No
From 0 feet to 20 feet

Seal Type:
☐ Neat Cement
☐ Cement Grout
☑ Concrete Grout

9. WATER LEVEL
Static water level 19 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling
Contractor
Address 7150 Placid St. L.V., Nv. 89119
Contractor
Nevada contractor's license number issued by the *State Contractor's Board* 51266
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2477-M
Signed Paul E. Dorr
By driller performing actual drilling on site or contractor
Date Dec 5 2013

(Rev. 06/10)

USE ADDITIONAL SHEETS IF NECESSARY

NAD 27
36.089537
-115.1711852