STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118809
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37128

1. OWNER Dewey Strip Holdings L.L.C.
MAILING ADDRESS 9440 W. Sahara Ave.# 240
Las Vegas Nv. 89117-8821

ADDRESS AT WELL LOCATION 4207 S. Las Vegas Blvd.
Las Vegas Nv. 89119

2. LOCATION SW ¼ SW ¼ Sec 28 T 21S N/S R 61 E
PERMIT/WAIVER No. 162-28-401-001
Issued by Water Resources — Parcel No.

Latitude 36.089509
Longitude -115.172017
UTM E
N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: County: Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	.3	0
Type 2		.3	.6	0
Sand W/Gravel		.6	3.5	3
Calichie		3.5	5.0	2
Gravel W/Sandy Clay		5.0	8.0	3
Calichie		8.0	10.5	3
LT.Sandy Clay		10.5	15.5	5
Calichie		15.5	17.0	2
Sand W/Gravel		17.0	23.0	6
Calichie		23.0	24.0	1
Clay,Sand,W/Gravel		24.0	27.0	3
PMP-1-25				

DCNR/DWR/SNGO
RECEIVED
DEC 04 2013

Date started 10/24/2013 , 20 13
Date completed 10/24/2013 , 20 13

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 27 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6.5/8	Inches	0	Feet	27	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Factory	Machine	-5"	25

Perforations:
Type of perforation Machine
Size of perforation 0.02
From 25 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 18'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 0 feet to 18 feet

9. WATER LEVEL
Static water level 19 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling (Contractor)
Address 7150 Placid St. L.V., Nv. 89119 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 51266
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2477-M
Signed (By driller performing actual drilling on site or contractor)
Date Dec 5 - 2013

(Rev. 06/10)
USE ADDITIONAL SHEETS IF NECESSARY

NAD 27 36.089537 -115.171852