STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118853
Permit No.
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70237
WELL NAME (If applicable):

1. OWNER/CLIENT NAME Gary Hardisty
MAILING ADDRESS 9230 Allen Rd.
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 9230 Allen Rd.
Fallon, NV 89406
Subdivision Name: County: Churchill

2. PLS LOCATION SW ¼ NE ¼ 12 Sec 17 N/S 28 E
PERMIT/WAIVER NO. DOM13-42 (Issued by Water Resources) 006-031-40 (Current Parcel No.)

Latitude 39.35347 UTM E ☐ NAD 27
Longitude 118.79071 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # 41026
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Brown Clay			0	2	2
Brown Sand			2	27	25
Green Clay			27	54	27
Black Clay			54	80	26
Gray Sand			80	89	9
Black Clay			89	118	29
Black Sand		X	118	127	9

replaces well log 41026

NAD27
39.353551°N
118.7897269°W

RECEIVED 2014 JAN -3 AM 11:12 STATE ENGINEERS OFFICE

Date started: 16-Jul, 20 13
Date completed: 17-Jul, 20 13

9. WELL CONSTRUCTION
Depth Drilled: 127 Feet Depth Cased: 127 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	127	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	10
6	4	.316	10	127

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 1/8
From 108 Feet To 125 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal		to		
☒ Neat Cement	0	to 100	☒ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	100	to 127	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 2 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality: unknown

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20		1HR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 Fallon, NV 89407 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 29064
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1753
Signed: [signature] (By driller performing actual drilling on site or contractor)
Date: 7/18/2013

(Rev. 06-12)

USE ADDITIONAL SHEETS IF NECESSARY