

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118890
Permit No. _____
Basin 162

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36273

1. OWNER JENNIFER OLIVER ADDRESS AT WELL LOCATION 1550 E KELLOGG RD
MAILING ADDRESS 8020 S RAINBOW BLVD #161 PAHRUMP
LAS VEGAS NV 89139 Subdivision Name: MESA OESTE County: NYE

2. LOCATION SW ¼ SE ¼ Sec 14 T 21S N/S R 53 E Latitude N 36°07'05.4" UTM E NAD 27
PERMIT/WAIVER No. 44-743-10 Longitude W 115°58'59.4" N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

| 6. LITHOLOGIC LOG | | | | |
|------------------------|--------------|------|-----|------------|
| Material | Water Strata | From | To | Thick-ness |
| EXISTING 8" STEEL WELL | | 0 | 140 | 140 |
| CLAY | | 140 | 165 | 25 |
| CALICHIE | WB | 165 | 178 | 13 |
| CLAY | | 178 | 190 | 12 |
| CALICHIE | WB | 190 | 210 | 20 |
| CLAY | | 210 | 225 | 15 |
| CALICHIE | WB | 225 | 235 | 10 |
| CLAY | | 235 | 240 | 5 |
| DCNR/DWR/SNBO RECEIVED | | | | |
| SEP 17 2013 | | | | |

Date started: 10-Aug, 20 13
Date completed: 10-Aug, 20 13

7. Water Level
Static water level: 110 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

| 8. WELL TEST DATA | | | |
|---|--------|-------------------------------|--------------|
| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| | | | |
| | | | |
| | | | |
| | | | |

| 9. WELL CONSTRUCTION | | | | |
|--------------------------|-----------------|-----------------|------|--|
| Depth Drilled | Feet | Depth Cased | Feet | |
| <u>240</u> | | <u>240</u> | | |
| HOLE DIAMETER (BIT SIZE) | | | | |
| | From | To | | |
| EXISTING | Inches <u>0</u> | Feet <u>140</u> | Feet | |
| <u>7-7/8</u> | Inches <u>0</u> | Feet <u>240</u> | Feet | |
| | Inches | Feet | Feet | |

| CASING SCHEDULE | | | | |
|--------------------|---------------------|-------------------------|-------------|------------|
| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
| <u>8</u> | <u>16.94</u> | <u>.188</u> | <u>0</u> | <u>14</u> |
| <u>4.5</u> | <u>2.37</u> | <u>.248</u> | <u>0</u> | <u>240</u> |

Perforations:
Type of perforation _____ SCREEN
Size of perforation 32
From 180 feet to 240 feet
From _____ feet to _____ feet

Annular Seal: Yes No EXISTING
 Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout to _____ Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured
Gravel Pack: Yes No 140 to 240 Pumped Poured
Type: _____
Bentonite Chips: Yes No to _____ Pumped Poured
Type: _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING
Contractor
Address 1220 MANSE RD
Contractor
PAHRUMP NV 89048
Nevada contractor's license number
issued by the State Contractor's Board 47333
Nevada driller's license number issued by the
Division of Water Resources, the on-site driller 2485
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 8/17/2013

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

Original log = 50397
36.1182033
-115, 9823098
NAD 27
10873