

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 118914 #1  
Permit No. \_\_\_\_\_  
Basin 097

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70782

1. OWNER WASHOE COUNTY  
MAILING ADDRESS 4930 ENERGY WAY  
RENO, NV

ADDRESS AT WELL LOCATION ALLEY SOUTH OF PRADER  
BETWEEN 14<sup>th</sup> + 15<sup>th</sup> ST  
Subdivision Name: \_\_\_\_\_ County: WASHOE

2. LOCATION SW 1/4 SE 1/4 Sec 5 T 19 N R 20 E  
PERMIT/WAIVER No. \_\_\_\_\_ CITY ROW  
Issued by Water Resources Parcel No. \_\_\_\_\_

Latitude 39 32 18" UTM E  NAD 27  
Longitude 119 45 38 N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other SANIC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SEE ATTACHED LITH LOG				
Plugged By Well Log 126711				

9. WELL CONSTRUCTION  
Depth Drilled 13 Feet Depth Cased 12.5 Feet  
HOLE DIAMETER (BIT SIZE)  
From 6 Inches To 13 Feet  
Casing Schedule  
Size O.D. (Inches) 2 Weight/Ft. (Pounds) \_\_\_\_\_ Wall Thickness (Inches) \_\_\_\_\_ From (Feet) 0 To (Feet) 8

Perforations:  
Type of perforation FACTORY SLOT  
Size of perforation .020  
From 8 feet to 12.5 feet  
Annular Seal:  Yes  No  
 Neat Cement  Pumped  Poured  
 Cement Grout  Pumped  Poured  
 Concrete Grout 3 to 1  Pumped  Poured  
 ≥30% Bentonite Grout  Pumped  Poured  
Gravel Pack:  Yes  No 12.5 to 4  Pumped  Poured  
Type: 10x20 SILICA #40 FINE  
Bentonite Chips:  Yes  No 4 to 3  Pumped  Poured  
Type: MEDIUM CHIPS

Date started: 6-26 20 13  
Date completed: 6-26 20 13

7. Water Level  
Static water level: 15 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name BOART LONGYEAR Contractor  
Address 7103 W. AUGUSTA AVE Contractor  
GLENDALE, AZ  
Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 0021976  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2434 M  
Signed K.L. Phillips  
By driller performing actual drilling on-site or contractor  
Date 6-26-13

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

USE ADDITIONAL SHEETS IF NECESSARY

