STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118931
Permit No. 61497
Basin No. 212

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34187
WELL NAME *(If applicable)*: 98

1. OWNER/CLIENT NAME Las Vegas Valley Water Dist.
MAILING ADDRESS 1001 S. Valley View ,LV.NV. 89153

DETAILED ADDRESS AT WELL LOCATION 8745 W Craig Rd.
Las Veags ,Nv.
Subdivision Name: *County:* Clark

2. PLS LOCATION NW ¼ SE ¼ 5 Sec 20s N/S 60 E
PERMIT/WAIVER NO. 61497 *Issued by Water Resources* | 13805701052 *Current Parcel No.*

Latitude UTM E 653941.0625 ☐ NAD 27
Longitude UTM N 4011980.25 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☒ Recondition: Original well log # 52752

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☒ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☒ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Bailed out well			1218	1228	10

DCNR/DWR/SNBO RECEIVED DEC 23 2013

original well log 52752
permit 61497

Date started: 19-Dec , 20 13
Date completed: 19-Dec , 20 13

9. WELL CONSTRUCTION
Depth Drilled: 1255 Feet Depth Cased: 1240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
48	Inches	0	Feet	70	Feet
34	Inches	70	Feet	1240	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
36	108	.375	0	70
24	94.5	.375	0	1240

PERFORATIONS:
Type of perforation: S.S Wire Wrapped Scr.
Size of perforation: 0.01
From 540 Feet To 620 Feet
From 700 Feet To 1220 Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal	0	to 300		
☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 300	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☐ Gravel Pack [> 0.2 in.]	305	to 1240	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Las Vagas Valley Water Dist. *Contractor*
Address 1001 S. Valley View ,Las Vegas, Nv. 89153 *Contractor*

Nevada contractor's license number as issued by the *State Contractor's Board:* N/A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1594

Signed: *By driller performing actual drilling on site or contractor*
Date: 12/23/2013

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY