

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30610

1. OWNER GMB LLC ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 NW 1/4 Sec. 02 T. 29 S. R. 63 E. CLARK County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources 250-02-201-006 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>HARD Boulders</u>		<u>0</u>	<u>65</u>	
<u>QUARTZ</u>		<u>65</u>	<u>200</u>	
<u>GREY QUARTZ water</u>		<u>200</u>	<u>290</u>	
<u>QUARTZ</u>		<u>290</u>	<u>315</u>	
<u>Red Clay</u>		<u>315</u>	<u>318</u>	
<u>Fractured Rock</u>		<u>318</u>	<u>500</u>	
<u>QUARTZ</u>		<u>500</u>	<u>530</u>	
<u>Fractured Rock</u>		<u>530</u>	<u>630</u>	
<u>QUARTZ</u>		<u>630</u>	<u>720</u>	

Hole bridged over at 450 ft. No water past 290 ft.

N 35° 27' #8 223 NAD 27  
W. 114° 54' #50 832

8. WELL CONSTRUCTION  
 Depth Drilled 720 Feet Depth Cased 450 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4 Inches 0 Feet 50 Feet  
8 3/4 Inches 50 Feet 720 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>1.188</u>	<u>+2</u>	<u>50</u>
<u>6 1/2</u>	<u>PVC</u>		<u>+1</u>	<u>450</u>

Perforations:  
 Type perforation FACTORY  
 Size perforation .032 Sieve Type \_\_\_\_\_  
 From 390 feet to 430 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 170 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality \_\_\_\_\_

TALK TO VERN  
 RE: THIS  
 REPLACEMENT Well.

Di: \_\_\_\_\_, 20 \_\_\_\_\_  
 Di: \_\_\_\_\_, 20 \_\_\_\_\_  
 7. 1-800- waiting for plug report  
 \_\_\_\_\_ (Hours)  
investigate @ and talk to Vern.

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Vernon H Dimick Contractor  
 Address 5360 N. Bonita Vista St  
L.V. NV. 89149  
 Nevada contractor's license number issued by the State Contractor's Board 10062  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552  
 Signed VH Dimick  
 By driller performing actual drilling on site or contractor  
 Date 07-23-07