STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119052
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37739

1. OWNER texas gambling & hall & hotel Inc
MAILING ADDRESS po box 379045 Las vegas nv 891347
ADDRESS AT WELL LOCATION N Las vegas [2101 texas star In
las vegas nv 89108

2. LOCATION NW¼ NE ¼ Sec 19 T 20S N/S R 61 E
PERMIT/WAIVER No. 8-001804 (Issued by Water Resources) 139-19-502-001 (Parcel No.)
Latitude 36.19971 Longitude 115.19569
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name: County: Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... has

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
asphalt		0	.3	0
type 2 fill		.3	1	1
silty sand		1	3	2
sandy clay w/ gravel		3	18	15
clayey silt		18	25	7
sand silt		25	28	3
clay sand		28	31	3
0831308r mw 8				

DCNR/DWR/SNBO
RECEIVED
AUG 19 2013

Date started 8/5/2013 , 20 13
Date completed 8/5/2013 , 20 13

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 31 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	31 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	pvc	40 sch	0	30

Perforations:
Type of perforation
Size of perforation 0.02
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 13.5
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 13.5 feet to 31 feet

9. WATER LEVEL
Static water level 21 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling (Contractor)
Address 7150 Placid St. L.V., Nv. 89119 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 51266
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2097
Signed (By driller performing actual drilling on site or contractor)
Date 8/9/2013

(Rev. 06/10)

USE ADDITIONAL SHEETS IF NECESSARY