

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 119058  
Permit No. \_\_\_\_\_  
Basin 228

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37513

1. OWNER CORVUS GOLD NEVADA, INC ADDRESS AT WELL LOCATION PASTO VALLEY BASIN  
MAILING ADDRESS 9137 KENDALL BLVD, #250  
HIGHLANDS RANCH, COLORADO 80129 Subdivision Name: \_\_\_\_\_ County: \_\_\_\_\_  
2. LOCATION NW 1/4 NE 1/4 Sec 27 T 10 N R 46 E Latitude UTM E 516 612.0 NAD 27  
PERMIT/WAIVER No. MO-2969 Longitude N 4099264.0  NAD 83/WGS 84  
issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>GRAVEL</u>	<u>NO</u>	<u>0</u>	<u>20'</u>	<u>20'</u>
<u>GRAVEL</u>	<u>NO</u>	<u>20'</u>	<u>40'</u>	<u>20'</u>
<u>SAND</u>	<u>NO</u>	<u>40'</u>	<u>105'</u>	<u>65'</u>
<u>SAND/GRAVEL</u>	<u>NO</u>	<u>105'</u>	<u>205'</u>	<u>100'</u>
<u>BEDROCK</u>	<u>NO</u>	<u>205'</u>	<u>205'</u>	<u>0</u>
<u>BLACK/BROWN BASALT</u>	<u>NO</u>	<u>205'</u>	<u>243'</u>	<u>38'</u>
<u>BLACK/BROWN BASALT</u>	<u>YES</u>	<u>243'</u>	<u>300'</u>	<u>57'</u>

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
HOLE DIAMETER (BIT SIZE)			
	From	To	
<u>14 3/4"</u>	Inches <u>0'</u>	Feet <u>20'</u>	Feet
<u>8 3/4"</u>	Inches <u>20'</u>	Feet <u>300'</u>	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2"</u>		<u>1/4"</u>	<u>0</u>	<u>300'</u>

Date started: AUGUST 25TH, 20 13  
Date completed: AUGUST 27TH, 20 13

7. Water Level  
Static water level: 2227' feet below land surface  
Artesian Flow: NO G.P.M. 2 P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)
<u>2</u>	<u>1 hr</u>		

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Boart Longyear Nevada Contractor  
Address PO Box 2748 Contractor  
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0073086  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2426

Signed Josh McMan  
Date 8-27-13  
By driller performing actual drilling on site or contractor

RECEIVED  
2013 OCT -3 AM 10:53  
STATE ENGINEERS OFFICE

DCNR/DWR/SNBO  
RECEIVED  
OCT 18 2013