(2)

DCNR/DWR/SNBO
RECEIVED

NOV 12 2013

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119063
Permit No. 19337
Basin 117

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69645

1. OWNER White Mountain Ranch
MAILING ADDRESS 71 LACRESTA Rd
ORINDA, Ca 94563

ADDRESS AT WELL LOCATION Dyer, NV 89010
Subdivision Name:
County: Esmeralda

2. LOCATION SE SE ¼ Sec 28 T 25 N R 35 E
PERMIT/WAIVER No. 19337-29540
Issued by Water Resources
Parcel No.

Latitude N37°43.591
Longitude W118°05.422
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other Well Abandon

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tryed To Pull Casing With Extractor Hammer And Rig It Would Not Budge. Preforated Casing to 47' feet. Hole Was Collapsed Shut at 260' Feet Drilled Through Rust and Fill to 478 ft. Then Fill on To Bottom at 501' Feet. Cut off Casing 3 Feet below Ground Level, Filled in. Original well log # 9948				

Date started: Oct 19, 20 13
Date completed: Oct 23, 20 13

9. WELL CONSTRUCTION
Depth Drilled 501' Feet Depth Cased 470' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14 3/4 Bit	Inches	0	Feet	501	Feet
used	Inches	to	Feet	Clean Out.	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10"	43	250	0	470'

Perforations:
Type of perforation Machine Sawed
Size of perforation 3/16" x 2" 6" Centers - 16 Row
From feet to feet
From 47' feet to 470' feet
From feet to feet
From 0 Ft. feet to 47' feet
From 1/4" x 2" x 2" 3 Rows Hott, feet
Preforator.

Annular Seal: ☐ Yes ☐ No
☒ Neat Cement 3' to 501' ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ 24% Bentonite Grout 50' to 501' ☒ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Track Drilling Inc.
Contractor
Address P. Box 599
Contractor
Silver Springs, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Nathaniel R. Track
By driller performing actual drilling on-site or contractor
Date Nov. 7/13

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

37.7265865
-118.0894269
NAD 27

(NSPO 3-08)

(O) 627