STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119070
Permit No.
Basin No. 212

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37077
WELL NAME *(If applicable)*: OMW76-72

1. OWNER/CLIENT NAME Ms RosePelino,AvisBudget Car Rent
MAILING ADDRESS 6 Sylvan Way
Parsippany, NJ, 07054

DETAILED ADDRESS AT WELL LOCATION
Wilbur Street & Lulu Ave, Las Vegas
Subdivision Name: *County:* Clark

2. PLS LOCATION NW ¼ NE ¼ 27 Sec 21S N/S 61 E
PERMIT/WAIVER NO. *Issued by Water Resources* *Current Parcel No.*

Latitude 36°5' 54" N UTM E ☒ NAD 27
Longitude 115° 8' 29" W UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☒ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Asphalt			0		
Type II Base				1	1
Caliche			1	11	10
Gravelly Sand			11	13	2
Caliche Gravel			13	23	10
Silt,gravel			23	27	4
silty sand gravel			27	29	2
lean clay with gravels			29	35	6
hard pack silty sand			35	40	5
silty gravel snad			40	41	1
hard sandy silt			41	47	6
lean clay with gravels			47	50	3
sandy silt gravels			50	52	2
poorly draded gravel clay			52	57	5
well graded sand			57	65	8
gravely lean clay			65	70	5
Caliche			70	74	4
lean clay with sand			74	77	3

DCNR/DWR/SNBO
RECEIVED
JAN 23 2014

Date started: 21-Nov , 20 13
Date completed: 21-Nov , 20 13

9. WELL CONSTRUCTION
Depth Drilled: 77 Feet Depth Cased: 72 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 5/8	Inches	0 Feet	77 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.68	0.154	- .50	77

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02
From 67 Feet To 72 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

Sanitary Seal	59 to 69			
☒ Neat Cement	-1 to 2		☒ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☒ Bentonite Chips	72 to 77		☒ Pumped	☐ Poured
☒ Bentonite Grout	2 to 59		☒ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☐ Gravel Pack [> 0.2 in.]	to		☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	64 to 72		☐ Pumped	☒ Poured
☐ Other, explain:	to		☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 67 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP
Contractor
Address 5566 Arrow Highway, Montclair, CA 91763
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board*: 00735355
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 2057
Signed: *By driller performing actual drilling on site or contractor*
Date: 12/23/13

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY

36, 09833
-115, 141388