STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119071
Permit No.
Basin No. 212

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37077
WELL NAME (If applicable): OMW76-40

1. OWNER/CLIENT NAME Ms RosePelino,AvisBudget Car Rentz
MAILING ADDRESS 6 Sylvan Way
Parsippany, NJ, 07054

DETAILED ADDRESS AT WELL LOCATION
Wilbur Street & Lulu Ave, Las Vegas
Subdivision Name: County: Clark

2. PLS LOCATION NW ¼ NE ¼ 27 Sec 21S N/S 61 E
PERMIT/WAIVER NO. Issued by Water Resources Current Parcel No.

Latitude 36°5' 54" N UTM E ☒ NAD 27
Longitude 115° 8' 29" W UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☒ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
Asphalt			0		
Type II Base				1	1
Caliche			1	11	10
Gravelly Sand			11	13	2
Caliche Gravel			13	23	10
Silt,gravel			23	27	4
silty sand gravel			27	29	2
lean clay with gravels			29	35	6
hard pack silty sand			35	40	5
silty gravel snad			40	41	1

DCNR/DWR/SNBO RECEIVED JAN 23 2014

Date started 26-Nov , 20 13
Date completed 26-Nov , 20 13

9. WELL CONSTRUCTION
Depth Drilled: 41 Feet Depth Cased: 40 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 5/8	Inches	0	Feet	41	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.68	0.154	- .50	40

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02
From 35 Feet To 40 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

Sanitary Seal	27	to	32		
☒ Neat Cement	-1	to	2	☒ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	40	to	41	☒ Pumped	☐ Poured
☒ Bentonite Grout	2	to	27	☒ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:					
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	32	to	40	☐ Pumped	☒ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 37 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP
Contractor
Address 5566 Arrow Highway, Montclair, CA 91763
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 00735355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2057

Signed: By driller performing actual drilling on site or contractor
Date: 12/23/13

(Rev. 08-12) **USE ADDITIONAL SHEETS IF NECESSARY**

36.09833
-115.141388