

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 119112  
Permit No. \_\_\_\_\_  
Basin 177

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69078

1. OWNER Brandon B. & Kaitelin E. Atkin ADDRESS AT WELL LOCATION Approx. 200' West of Hwy. 232 & 13.5 miles south of City of Wells  
MAILING ADDRESS H.C. 60 #147 State Hwy 232 Wells, NV 89835 Subdivision Name: \_\_\_\_\_ County: Eldorado

2. LOCATION SW 1/4 SE 1/4 Sec 1 T 350 S R 61 E Latitude 40.937794 N UTM E  NAD 27  
PERMIT/WAIVER No. DDP-108-002 Longitude 115.032043 W N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  New Well  Replace  Recondition  Deepen  Other  
4. PROPOSED USE  Domestic  Irrigation  Test  Monitor  Municipal/Industrial  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silt, Sand, Gravel, Granite		0	30	30
Clay, Sand, Cobbles, Boulders, Granite		30	145	115
Clay, Sand		145	200	55
Sand, Gravel, Cobbles, Granite	X	200	230	30
Sand, Cobbles		230	250	

RECEIVED  
2014 FEB -3 PM 11:04  
STATE ENGINEERS OFFICE

MAD27  
40.937794 N  
115.031163 W

9. WELL CONSTRUCTION  
Depth Drilled 250 Feet Depth Cased 250 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 250 Feet  
9 7/8 Inches  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
6.625 SPR17 .250 2 60  
6.625 SPR17 .250 60 190

Perforations:  
Type of perforation Mill  
Size of perforation 1/8 x 2 1/2 x 6  
From 190 feet to 210 feet  
From 230 feet to 250 feet  
Annular Seal:  Yes  No  
 Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout 0 to 100  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured  
Gravel Pack:  Yes  No 100 to 250  Pumped  Poured  
Type: Pea Gravel  
Bentonite Chips:  Yes  No  Pumped  Poured  
Type: \_\_\_\_\_

Date started: Dec. 11, 20 13  
Date completed: Jan. 23, 20 14

7. Water Level  
Static water level: 40 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>11</u>		<u>3 HOURS</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Gardner Brothers Drilling Contractor  
Address PO BOX 965 Contractor  
Enterprise UT 84725  
Nevada contractor's license number issued by the State Contractor's Board 0068459  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2459  
Signed Trevor Gardner  
By driller performing actual drilling on-site or contractor  
Date 1-31-14