

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT**

**OFFICE USE ONLY**

Log No. 119134  
 Permit No. \_\_\_\_\_  
 Basin 19

**PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 71467

1 OWNER Department of the Navy ADDRESS AT WELL LOCATION  
 MAILING ADDRESS 4755 Pasture Rd., Fallon, NV NW corner of parking lot behind building 1095  
 Subdivision Name: BAT-3-AU County: Churchill  
 2 LOCATION SW  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec 15 T 18N N/S R 23 E Latitude 39. 25 29.22 N UTM E  NAD 27  
 PERMIT/WAIVER No. CDL-011-01 Longitude -118. 42 57.06 W N  NAD 83/WGS 84  
Issued by Water Resources Parcel No.

3 TYPE OF WELL Is this well being plugged because a replacement well was drilled? No Is there an existing well log? NA  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 If yes, what is replacement well NOI? \_\_\_\_\_ If yes, what is NDWR well log #? \_\_\_\_\_

4 EXISTING WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	21	Feet
EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>.75</u>		<u>Sch. 40</u>	<u>0</u>	<u>21</u>

7 WELL PLUGGING PROCEDURE

Was well cleaned out to total depth?  yes  no  
 If well was not cleaned out to total depth, please explain why:  
Bottom well was tagged  
 Was the well contaminated?  yes  no  
 Was the casing pulled?  yes  no  
 Was the casing over drilled?  yes  no

Existing Perforations:

Type of perforation	Size of perforation	From	feet to	feet

If casing was left in place, please show where additional perforations were made:  
 Additional Perforations:  
 Type of perforator used: none

From	feet to	feet	Number of perfs per linear foot

5 WATER LEVEL

Static water level 7 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ ° F Quality \_\_\_\_\_

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<u>0</u>	<u>21</u>	<u>feet</u>	<u>neat</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments  
Grouted to the surface completion was in cement  
plug withdrawn log  
NAD 27  
39.424 5165 N  
114.714 816 80 W

Neat Cement Fluid Weight 1 lbs/gal  
 Bentonite Grout 4 % bentonite  
 Date Started 1/15/2014  
 Date Completed 1/15/2014

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name National EWP  
 Contractor  
 Address 500 Main St. Woodland, CA 95695  
 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0075355  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2111  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 1-27-14