

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY  
Log No. 119172  
Permit No. \_\_\_\_\_  
Basin 19

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68833

1 OWNER Department of the Navy  
MAILING ADDRESS 4755 Pasture Rd., Fallon, NV  
ADDRESS AT WELL LOCATION 500' north of the siren tower 300' south of the Delta runway  
Subdivision Name: NS-UK-BS1-25 County: Churchill  
2 LOCATION NE 1/4 SE 1/4 Sec 22 T 18N N/S/R 25 E Latitude 39 24 31.50 N UTM E  NAD 27  
PERMIT/WAIVER No. 006-01-01 Longitude -118. 42 27.23 W N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. 29

3 TYPE OF WELL  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
Is this well being plugged because a replacement well was drilled? No  
If yes, what is replacement well NOI? \_\_\_\_\_  
Is there an existing well log? NA  
If yes, what is NDWR well log #? \_\_\_\_\_

4 EXISTING WELL CONSTRUCTION  
Depth Drilled Feet Depth Cased 10 Feet

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>Sch. 40</u>	<u>0</u>	<u>10</u>

7 WELL PLUGGING PROCEDURE  
Was well cleaned out to total depth?  yes  no  
If well was not cleaned out to total depth, please explain why: Bottom of the well was tagged  
Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no  
If casing was left in place, please show where additional perforations were made:  
Additional Perforations: none  
Type of perforator used: none

From	feet to	feet	Number of perfs per linear foot

5 WATER LEVEL  
Static water level 8.4 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

8 WELL PLUGGING MATERIALS  
Material Used  
From 0 feet to 10 feet Neat  Pumped  Poured  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  Pumped  Poured  
Neat Cement Fluid Weight 5 gal lbs/gal  
Bentonite Grout \_\_\_\_\_ % bentonite

6 Additional Notes or Comments  
completion was pulled and filled with native soil  
plug into main well log  
Feb 24  
39.408531°N  
118.706582°W

9 DRILLER'S CERTIFICATION  
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.  
Name National EWP Contractor  
Address 500 Main St. Woodland, CA 95695 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 0075355  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2111  
Signed [Signature]  
Date 11-27-14  
By driller performing actual drilling on site or contractor