STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119490
Permit No.
Basin 069

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70760

1. OWNER Pauline Lambert
MAILING ADDRESS PO BOX 1746
Winnemucca NV 89446

ADDRESS AT WELL LOCATION Georgia Circle
Winnemucca NV.
Subdivision Name: Delaney County: Humboldt

2. LOCATION NE ¼ SW ¼ Sec 10 T 37 N/S R 38 E
PERMIT/WAIVER No. R-806 | 006-613-01
Issued by Water Resources | Parcel No.

Latitude N 41° 05.828
Longitude W 117° 41.405
UTM E
N
■ NAD 27
☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand	NO	0	6	6
Coarse Gravel Sand	NO	6	40	34
Clay Sand Gravel	Yes	40	100	60

RECEIVED
2014 FEB 24 AM 11:50
STATE ENGINEERS OFFICE

Nad 27
41.097133 N
117.690083 W

Date started: 1-31, 20 14
Date completed: 2-1, 20 14

9. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/8	Inches	0	Feet	100	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 3/8	Steel	.188	0	20
6 3/8	PVC	Sand 40	20	100

Perforations:
Type of perforation Slot
Size of perforation .020
From 60 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 20 ☐ Pumped ■ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ■ Yes ☐ No 50 to 100 ☐ Pumped ■ Poured
Type: 3/8 Pea
Bentonite Chips: ■ Yes ☐ No 20 to 50 ☐ Pumped ■ Poured
Type: 3/8"

7. Water Level
Static water level: 40 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	NA	3½

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc.
Contractor
Address 5140 Jungo Rd.
Contractor
Winnemucca NV. 89445
Nevada contractor's license number issued by the State Contractor's Board ~~1563~~ 76278
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 2-6-14

(Rev 05-05)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627