STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 11959
Permit No.
Basin No. 067

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67150
WELL NAME (If applicable): MW-2

1. OWNER/CLIENT NAME Jose Rios/7-Eleven, Inc.
MAILING ADDRESS PO Box 711
Dallas, TX 75221

DETAILED ADDRESS AT WELL LOCATION Facility ID: 4-001103
6150 S McCarran Blvd. Reno, NV
Subdivision Name: County: Washoe

2. PLS LOCATION NE ¼ NE ¼ 36 Sec 19 N/S 19 E
PERMIT/WAIVER NO. 41-001103 (Issued by Water Resources) 040-952-14 (Current Parcel No.)

Latitude 39.47653 UTM E ☒ NAD 27
Longitude -119.791784 UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Dry rocky silt			0	40	40
Wet silty clay			40	55	15

2014 FEB 20 AM 11:33 STATE ENGINEERS OFFICE

Nad 27
39.476533°N
119.791784°W

Date started: 19-Dec, 20 13
Date completed: 12/20/2013, 20

9. WELL CONSTRUCTION
Depth Drilled: 55 Feet Depth Cased: 55 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	55	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		Sch 40	0	55

PERFORATIONS:
Type of perforation: Slot
Size of perforation: 0.02
From 35 Feet To 55 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

		to		
☐ Sanitary Seal				
☐ Neat Cement			☐ Pumped	☐ Poured
☐ Cement Grout			☐ Pumped	☐ Poured
☒ Concrete Grout	0	31	☐ Pumped	☐ Poured
☒ Bentonite Chips	31	33	☐ Pumped	☒ Poured
~~☒ Bentonite Grout~~	~~0~~	~~31~~	☐ Pumped	☒ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☐ Gravel Pack [> 0.2 in.]			☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	33	55	☐ Pumped	☒ Poured
☐ Other, explain:			☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 40 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Plugged by log (2000?)		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Cascade Drilling, L.P. (Contractor)
Address 3000 Duluth Street West Sacramento, CA 95691 (Contractor)

Nevada contractor's license number as issued by the *State Contractor's Board:* 73966
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1977

Signed: (By driller performing actual drilling on site or contractor)
Date: 11-Feb-14

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY