WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 119565
Permit No.
Basin 163

NOTICE OF INTENT NO. 36796

1. OWNER John & Pessy Ellenburg
MAILING ADDRESS P.O box 9570
Las Vegas NV 89193
ADDRESS AT WELL LOCATION Gypsum + Polona
Sandy Valley NV

2. LOCATION SE ¼ SW ¼ Sec. 23 T. 24 N/S R. 56 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 200-23-401-023 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Loam		0	2	2
Clay		2	22	20
Caliche		22	25	3
Clay		25	48	23
Caliche		48	52	4
Clay	W.B	52	62	10
Caliche		62	69	7
Clay		69	80	11
Caliche	W.B	80	83	3
Clay		83	93	10
Caliche	W.B	93	101	8
Clay		101	125	24
Caliche	W.B	125	135	10

35°50.487N
115°39.917W
elev 2666

DCNR/DWR/SNBO
RECEIVED
FEB 11 2014

Date started 1-24-14, 20 14
Date completed 1-24-14, 20 14

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	unknown	1

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10.5	0	135

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.95		Certilock	0	135
6 5/8		.188	+2	8

Perforations:
Type perforation factory Screen
Size perforation .030in
From 95 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 65 ft feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Budset Drilling Contractor
Address 1170 Dandy Pahrump NV 89060 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0077029
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed By driller performing actual drilling on site or contractor
Date 2-3-14

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY 35.8415709 -115.6643923 NAD 27

(07)-627