

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 119690  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36835

1. OWNER Matt Kershaw Clark County Credit Union ADDRESS AT WELL LOCATION 3940 N. Martin L. King Blvd  
MAILING ADDRESS PO Box 36490 Las Vegas, NV 89133-6490 Subdivision Name: \_\_\_\_\_ County: \_\_\_\_\_

2. LOCATION NW 1/4 NE 1/4 Sec 9 T 20 N R 61 E Latitude 36°13'52.31" N UTM E \_\_\_\_\_  NAD 27  
PERMIT/WAIVER No. 139-09-501-021 Longitude 115°09'40.16" W N \_\_\_\_\_  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Asphalt</u>		<u>0</u>	<u>.5</u>	<u>.5</u>
<u>clay w/sand</u>		<u>.5</u>	<u>15</u>	<u>14.5</u>
<u>Partially cemented</u>		<u>15</u>	<u>20</u>	<u>5</u>
<u>clay w/sand</u>		<u>20</u>	<u>35</u>	<u>15</u>
<u>Partially cemented</u>		<u>35</u>	<u>40</u>	<u>5</u>
<u>Sandy gravel w/sand</u>		<u>40</u>	<u>51</u>	<u>11</u>
<u>caliche intermittent layer</u>		<u>51</u>	<u>65</u>	<u>14</u>
<u>clay w/sand</u>		<u>65</u>	<u>85</u>	<u>20</u>
<u>sand w/gravel</u>	<u>X</u>	<u>85</u>	<u>90</u>	<u>5</u>
<u>clay</u>		<u>90</u>	<u>95</u>	<u>5</u>

DCNR/DWR/SNRC  
RECEIVED  
FEB 19 2014

9. WELL CONSTRUCTION

Depth Drilled 95' Feet Depth Cased 95' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>8"</u>	<u>0</u>	<u>95</u>	<u>95</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>95</u>

Perforations:

Type of perforation Factory slot  
Size of perforation .020

From 75 feet to 95 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

<input type="checkbox"/> Neat Cement	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Cement Grout	<u>2'</u> to <u>70</u>	<input checked="" type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack:  Yes  No 73 to 95  
Type: #3 silica

Bentonite Chips:  Yes  No 70 to 73  
Type: Hole plug

Date started: 2-5 20 14  
Date completed: 2-5 20 14

7. Water Level  
Static water level: 8.0 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Elite Drilling Inc.  
Address 4255 W. Post Rd.  
Las Vegas, NV 89118  
Nevada contractor's license number 0054931  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869

Signed [Signature]  
By driller, performing actual drilling on-site or contractor  
Date 2/13/14