STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119462
Permit No.
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71063
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Steve Felton
MAILING ADDRESS 2130 Bafford Lane
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 7807 Curry Rd.
Fallon, NV 89406
Subdivision Name: *County:* Churchill

2. PLS LOCATION NW ¼ NE ¼ 2 Sec 17N N/S 28 E
PERMIT/WAIVER NO. 006-031-82
Issued by Water Resources *Current Parcel No.*

Latitude 39.37224 N UTM E ☐ NAD 27
Longitude 118.80743 W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Brown Sand			0	6
Brown Clay			6	14
Gray Sand			14	26
Gray Clay			26	28
Black Clay			28	46
Black Sand			46	74
Black Clay			74	82
Green Clay			82	105
Green Sand		X	105	120

Date started: 15-Jan, 20 14
Date completed: 17-Jan, 20 14

9. CONSTRUCTION
Depth Drilled: 120 Feet Depth Cased: 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	0	20
6.625	4	.316	20	120

ANNULAR MATERIALS

Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	5	to 105	☒ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	105	to 120	☐ Pumped	☐ X Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 0.125

From	Feet	To	Feet
115	Feet	120	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. *WATER QUALITIES*
Static water level: 7 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality: unknown

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Co
Contractor
Address P.O. Box 1265 Fallon, NV 89406
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2307

Signed:
By driller performing actual drilling on site or contractor
Date: 2/13/2014

NAD 27
39.37232 N
118.80644 W

JAN 21 AM 10:26
STATE ENGINEERS OFFICE