STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119703
Permit No.
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71302
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME Wayne Stark
MAILING ADDRESS 400 Sheckler Cut-Off
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 400 Sheckler Cut-Off
Fallon, NV 89406
Subdivision Name: *County:* Churchill

2. PLS LOCATION SE ¼ NE ¼ 30 Sec 19N N/S 28 E
PERMIT/WAIVER NO. *Issued by Water Resources* 008-573-17 *Current Parcel No.*

Latitude 39.48282 N UTM E ☐ NAD 27
Longitude 118.87627 W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # N/A
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Brown Sand			0	45
Brown Clay			45	51
Green Clay			51	55
Green Clay Black Sand			55	62
Brown Sand			62	82
Green Clay			82	102
Gray Clay Sand			102	134
Brown Clay			134	150
Brown Sand		X	150	160

Rec'd MAR 17 2014 ID: 26
NV ENGINEERS OFFICE
Nad 27
39.48282°N
118.87627°W

Date started: 18-Feb , 20 14
Date completed: 19-Feb , 20 14

7. WATER QUALITIES
Static water level: 20' Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool ° Fahrenheit
Water Quality: unknown

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
replace unknown well log		

9. CONSTRUCTION
Depth Drilled: 160 Feet Depth Cased: 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	+2	18
6.625	4	.316	18	160

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	5	to 145	☒ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	145	to 160	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 0.125

From	Feet	To	Feet
155	Feet	160	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Co *Contractor*
Address P.O. Box 1265 Fallon, NV 89406 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board*: 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 1753
Signed: Wayne Stark *By driller performing actual drilling on site or contractor*
Date: 3/3/2014

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.